

ADDENDUM #1

J.M. BEVINS COMMUNITY CENTER – WASTEWATER TREATMENT PLANT

Issue Date: January 2, 2025

Issuing Office: Terra Tech Engineering

Please sign this sheet include it with your proposal.

Acknowledgement of Receipt:

Name: _____ **Date:** _____

Other:

1. The surge tank on the drawings shall be changed from a 2000-gallon aeriated tank to a 1,500-gallon aeriated surge tank.
2. A pump shall be installed in the aerated surge tank to feed the treatment plant at 40 gallons per hour.